


PLASTIC PIPE

NOTES

1. The culvert ends shall be beveled to match the embankment or ditch slope and shall not be beveled flatter than 3H:1V. When slopes are between 3H:1V and 6H:1V, shape the slope in the vicinity of the culvert end to ensure that no part of the culvert protrudes more than 4" above the ground line.
2. Field cut of culvert ends is permitted.
3. All new Culvert pipe shall be double-wall Corrugated High Density Polyethylene drainage pipe with a smooth inner wall.



**Office of the
ISLAND COUNTY ENGINEER**
1 NE 6th Street
Coupeville, WA 98239-5000



APPROVED BY:
William E. Oakes
William E. Oakes, P.E.
COUNTY ENGINEER
DATE: 6/29/08

TITLE:
**Island County Public Works
End Culvert Pipe Details**

SCALE:
NOT TO SCALE
SHEET 1 OF 1